

Building

Regulations Advisory Committee

Certificate of Accreditation

Amendment 3

Name of product: INSULCON PANEL EXTERNAL CLADDING SYSTEM

Product description: External panel cladding system

Description of the purpose and use of the building product: Suitable for use as a wall cladding system on Class 1 and 10, and Class 2 to 9 buildings of Type 'C' construction only

Regulation/s in relation to which the building product is accredited: The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the Insulcon Panel External Cladding System complies with the following Performance Requirements:

Volume One B1P1, B1P2, F1P4, F3P1 and Volume 2 H1P1, H2P2, H2P3 of the Building Code of Australia as adopted by the *Building Regulations 2018*, to the extent that those clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the system, subject to the following conditions:

Conditions to which the accreditation is subject:

1. The system must be installed on framing with stud spacing at a maximum of 600 mm centers and in accordance with the Insulcon Panel System Installation Manual (Revision 7.6 – 11.09.25) except that it must not be used in areas with a wind classification of more than N4w under AS 4055 and the maximum vertical fastener spacing (mm) must be as follows –

Stud spacing (mm)	Location (mm)	Wind classification to AS 4055			
		N1	N2	N3	N4
450	Within 1200 of building edge	365	365	365	275
	Elsewhere	365	365	365	365
600	Within 1200 of building edge	365	365	365	275
	Elsewhere	365	365	365	365

2. The maximum installation height above ground level must not be more than 7 metres.
3. The product is only to be installed on timber and steel framework.
4. The fastenings must be in accordance with the following –

Building

Regulations Advisory Committee

Fasteners	75mm Panels	40mm Panels
Screw	10g x 100mm CSK Head coarse ribbed Class 3	10g x 75mm CSK Head coarse ribbed Class 3
Washer	Insulcon approved plastic washers	

5. All fastenings must be protected against corrosion as set out in Table 5.6.5d of the Building Code of Australia 2022 (Amendment 1)
6. All fixtures and features attached to the wall must be secured into the wall framing.
7. The product must only be used with breathable sarking behind the panels.
8. Render of the panels must be applied strictly in accordance with the render manufacturer's installation requirements. A minimum thickness of 5mm of render per coat must be applied to the external surface, with a minimum of 2 coats for raw panel option.
9. A minimum ground clearance of 100mm above paved surfaces and 150mm above unpaved or landscaped surfaces are to be provided.

**The name,
address and
Australian
business
number of the
holder of the
accreditation:
Certificate
number:**

Insulcon Pty Ltd
34 Swift Way
DANDENONG SOUTH VIC 3175

ABN 96 887 479 796

V11/02-A3

Date of issue: 10/10/2025

Refer to the Historical Details page of this Certificate.
This Certificate is only valid when reproduced in its
entirety.

**Date of expiry of
accreditation:** 10/10/2028

Signature:



Heidi Smith
Nominated Chair, Building Regulations Advisory Committee

