

## AUDIT

### 93: LPG Type A Installation 94: Other Types of gas (caravans and mobile homes)

#### Checklist

#### Performance and Compliance Check Level 1 and Level 2 Faults

##### LEVEL 1

- ☐ Is the installation gas tight?
- ☐ Has permanent and unrestricted ventilation been provided?
- ☐ Are all clearances for the hotplate achieved?
- ☐ Are all clearances for the hot water unit achieved?
- ☐ Are all requirements for the cylinder and compartment achieved?
- ☐ Do the drain size, facing direction, and location comply?
- ☐ Is all pipework support at correct intervals?
- ☐ Are all penetrations into the van sealed appropriately?
- ☐ Has all required signage been installed?
- ☐ If applicable, is a tempering valve installed?
- ☐ Have all permanent gas appliances been connected to bayonet fittings if required, and are shut-off valves in the open position?
- ☐ Are the hose assemblies approved and appropriately marked?
- ☐ Are all drainage holes the required distance from an ignition source and facing the correct direction?
- ☐ Have the approved materials, components, and manual shut-off valves been used?
- ☐ Have approved appliances been installed?
- ☐ Have all flue clearances been achieved?
- ☐ Is the minimum vertical dimension of the free ventilation opening 6 mm?
- ☐ Is the gas bottle fixing fit for its intended purpose?



## LEVEL 2

- ☐ Have any components been replaced that require a compliance certificate to be lodged for the work or that are over the prescribed combined amount?
- ☐ Where required, has an exemption been submitted and approved for design alterations?
- ☐ Have the manufacturer's installation instructions been adhered to?
- ☐ Has the class of plumbing been indicated on the compliance certificate?

## REFERENCES

Does the installation comply with the minimum industry standards:

- AS/NZS 5601: Parts 1 & 2 – Gas installations
- *Gas Safety Act 1997*
- Gas Safety (Gas Installation) Regulations 2008 – Part 2: Appliances, Part 3: Gasfitting work – gas safety (67) (69)
- AS/NZS 1596 – The Storage and Handling of LP Gas
- The relevant manufacturer's installation instructions

## NOTES

The standards and audit items listed on this checklist are intended as a guide only and are not an exhaustive list.

Other standards may be applicable to the installation and should be referenced as required, additionally Audit items may alter depending on actual work conducted and the final installation.

Practitioners are advised to check that they are using the most current edition of the prescribed standards at the time of installation.