

AUDIT

96: Irrigation – Non-Agricultural (Applies Only to Pressurised Zones)

Checklist

Performance and Compliance Check Level 1 and Level 2 Faults

LEVEL 1

- Are the materials used fit for their intended purpose and, where required, appropriately authorised?
- Are the cross-connection control and backflow provisions in accordance with the standards?
- Where required, has the installation been correctly identified as non-drinking water?
- Where required, has the installation been correctly identified as rainwater?
- Has the installation passed the required hydrostatic test?

LEVEL 2

- Does the installation have the required flow rates?
- Does the installation comply with the proximity to other services?
- Do all valves perform correctly?
- Where required, does the installation have isolating valves?
- Does the installation have the correct pipework support?
- Does the installation have the correct depth of cover?
- Where required, does the installation have appropriate frost protection?
- Are non-drinking water sprinkler heads coloured purple?
- If installed, does the registered break tank meet requirements?
- Where required, has a modification application been submitted and approved?
- Have manufacturer's instructions been adhered to?
- Has the class of plumbing been indicated on the compliance certificate?
- Where relevant, has documentation for a Performance Solution been provided?
- Where non-drinking water has been applied, have the conditions of connection been adhered to?



REFERENCES

Does the installation comply with the minimum industry standards:

- AS/NZS 3500.1: Plumbing and drainage Part 1: Water services
- AS/NZS 2845.2: Water supply backflow prevention devices – registered air gaps and registered break tanks
- The requirements of Part B4 of the Plumbing Code of Australia
- The relevant manufacturer's installation instructions
- The *Plumbing Regulations* 2018

NOTES

The standards and audit items listed on this checklist are intended as a guide only and are not an exhaustive list.

Other standards may be applicable to the installation and should be referenced as required, additionally, Audit items may alter dependent on the actual work conducted and the final installation.

Practitioners are advised to check that they are using the most current edition of the prescribed standards at the time of installation.